

**GENERAL NOTES**

1. ALL EXISTING PLUMBING AND PIPING WAS TAKEN FROM EXISTING DOCUMENTS. VERIFY EXISTING PIPE SIZES AND LOCATIONS PRIOR TO STARTING WORK.
2. COORDINATE ALL WORK AND INTERRUPTIONS WITH THE OWNER PRIOR TO BEGINNING WORK.

**NEW WORK PLAN NOTES**

- ① BALANCING VALVE.
- ② ASSE 1070 APPROVED MIXING VALVE.
- ③ GAS PRESSURE REGULATING VALVE, INLET PRESSURE OF 2 PSI AND AN OUTLET PRESSURE OF 14" WC.
- ④ GAS SOLENOID VALVE WITH MANUAL RESET CONNECTED TO THE FIRE ALARM SYSTEM, 120V, NORMALLY CLOSED.
- ⑤ PROVIDE AN ELECTRIC TRAP PRIMER EQUAL TO SIOUX CHIEF 695-ES01 FOR FLOOR DRAIN.
- ⑥ AIR COMPRESSOR PROVIDED BY OTHERS. REVIEW FINAL CONNECTIONS WITH MANUFACTURER.
- ⑦ COORDINATE WITH ELECTRICAL FOR GENERATOR FINAL CONNECTION REQUIREMENTS PRIOR TO INSTALLATION.
- ⑧ GAS PRESSURE REGULATING VALVE, INLET PRESSURE OF 2 PSI AND AN OUTLET PRESSURE OF 11" WC.
- ⑨ INTAKE AND EXHAUST FLUE UP THRU ROOF.


Stephen Boruff, AIA  
Architects + Planners, Inc.  
AAC 002226  
Architecture  
Planning  
Interior Architecture

901  
Northpoint Parkway  
Suite 101  
West Palm Beach  
Florida 33407

J L R D JOHNSON, LEVINSON  
BALAN, DAVILA, INC.  
CONSULTING ENGINEERS  
1450 Centrepark Boulevard, Suite 350  
West Palm Beach, Florida 33411  
(561) 888-2303 (561) 888-2302 Fax  
www.jlr-dinc.com

Ruben Ortega Blanco, P.E. 90645  
Ward C. Connors, P.E. 45639

New Kitchen  
Facility for



701 Boutwell Road  
Lake Worth, FL 33461



Project No. 22.046  
24 February 2023  
Bidding, Permit and  
Construction

P  
4  
JLRD PROJECT NO:  
122110