



TYPICAL WASTEWATER SERVICE CONNECTION




TRENCHING





- NOTES:
1. U.S. FOUNDRY NO. 7621 REVERSIBLE HANDHOLE RING AND COVER OR APPROVED EQUAL SHALL BE USED, COVER TO BE CAST WITH "S" IN THE CENTER.
 2. CLEAN OUT REQUIRED ON ALL SERVICES AT PROPERTY LINE.
 3. STANDARD WYE SHALL BE USED AT CLEAN OUT.
 4. ALL PIPE AND CLENOUT SHALL BE 6" MIN.

CLEAN OUT



6" CONCRETE PAVEMENT SECTION



- NOTES:
1. THERE SHALL BE, IN ALL CASES, A MINIMUM OF 12" SEPARATION BETWEEN WATER MAINS AND FORCE MAINS.
 2. WHEREVER POSSIBLE WATER MAINS SHALL PASS OVER FORCE MAINS OR STORM SEWERS.
 3. FITTINGS SHALL BE RESTRAINED WITH MEGALUGS AND TIE RODS BETWEEN OFFSET FITTINGS. THRUST BLOCKS SHALL ONLY BE USED WITH THE APPROVAL OF THE ENGINEER.
 4. THE DEFLECTION TYPE CROSSING IS PREFERRED. SEE SPECIFICATIONS AND MANUFACTURER'S SUBMITTAL FOR MAXIMUM DEFLECTION ALLOWED.
 5. A MINIMUM OF 12" VERTICAL SEPARATION BETWEEN WATER MAINS AND STORM SEWERS SHALL BE MAINTAINED. WHERE THIS IS NOT POSSIBLE WATER MAIN SHALL BE D.I.P. WITH NO LESS THAN 6" SEPARATION.

PRESSURE PIPE CONFLICT

90%
SUBMITTAL

KEITH JACKSON, P.E., PROFESSIONAL ENGINEER LICENSE NO. 37289
THIS DOCUMENT HAS BEEN ELECTRONICALLY SIGNED AND
SEALED BY KEITH JACKSON, P.E. USING A SHA-1 AUTHENTICATION CODE.
PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND
SEALED AND THE SHA-1 AUTHENTICATION CODE MUST BE VERIFIED ON ANY
E L E C T R O N I C C O P I E S .



Know what's below.
Call before you dig.

REVISIONS		NO.	DATE	REMARKS	BY

© COPYRIGHT 2022 BY ENGINEERING GROUP, INC. THIS DRAWING IS PROVIDED FOR INFORMATIONAL PURPOSES ONLY. UNLESS SIGNATURED AND SEALED BY THE ENGINEER REPRESENTING ENGINEERING GROUP, INC.		KEITH JACKSON, P.E. NO. 37289	
---	--	----------------------------------	--

FOOD BANK BOUTWELL RD, LAKE WORTH PALM BEACH COUNTY DETAILS	
--	--

A Higher Standard of Excellence engenuity group inc. ENGINEERS • SURVEYORS • GIS SERVICES	
1280 N CONGRESS AVE, SUITE 101 WEST PALM BEACH, FLORIDA 33409 PH (561) 655-1151 • FAX (561) 832-5390 WWW.ENGENUITYGROUP.COM CERTIFICATE OF AUTHORIZATION #7095	

DATE	DECEMBER 2022	DRAWN	KG	PROJECT	KJ	PROJECT	RB	CHECKED	KJ
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	
DATE		DRAWN		PROJECT		PROJECT		CHECKED	

JOB NO.
22081.01