

NOTE: The content of this drawing originates directly from the Florida Building Code, Accessibility, and is provided herein as reference, covering design intent and construction requirements as it relates to accessibility. This drawing includes technical requirements for accessibility to sites, facilities, buildings, and elements by individuals with disabilities. The requirements are to be applied during the construction, additions to, and alteration of sites, facilities, buildings and elements.






1 CLEAR WIDTH OF AN ACCESSIBLE ROUTE
NOT TO SCALE

2 FIGURE 304.3.2
T-SHAPED TURNING SPACE
NOT TO SCALE

3 FIGURES 305.3 AND 305.5
CLEAR FLOOR OR GROUND SPACE
NOT TO SCALE

4 FIGURES 305.7.1 AND 305.7.2
MANEUVERING CLEARANCE IN AN ALCOVE
NOT TO SCALE

5 FIGURE 403.5.2
CLEAR WIDTH AT TURN
NOT TO SCALE



6 FIGURES 306.2 AND 306.3
TOE CLEARANCE AND KNEE CLEARANCE
NOT TO SCALE

7 FIGURES 308.2.1 AND 308.2.2
UNOBSTRUCTED FORWARD REACH AND
OBSTRUCTED HIGH FORWARD REACH
NOT TO SCALE

8 FIGURES 308.3.1 AND 308.3.2
UNOBSTRUCTED SIDE REACH AND
OBSTRUCTED HIGH SIDE REACH
NOT TO SCALE

9 FIGURES 609.2.2 AND 609.3
GRAB BAR CROSS SECTIONS AND SPACING
NOT TO SCALE

10 FIGURE 602.5
DRINKING FOUNTAIN SPOUT LOCATION
NOT TO SCALE

TABLE 404.2.4.1
MANEUVERING CLEARANCE AT MANUAL SWINGING DOORS AND GATES


Type of Use		Minimum Maneuvering Clearance	
Approach Direction	Door or Gate Side	Perpendicular to Doorway	Parallel to Doorway (beyond latch side unless noted)
From front	Pull	60 inches (1525 mm)	18 inches (455 mm)
From front	Push	48 inches (1220 mm)	0 inches (0 mm) ¹
From hinge side	Pull	60 inches (1525 mm)	36 inches (915 mm)
From hinge side	Pull	54 inches (1370 mm)	42 inches (1065 mm)
From hinge side	Push	42 inches (1065 mm) ²	22 inches (560 mm) ³
From latch side	Pull	48 inches (1220 mm) ⁴	24 inches (610 mm)
From latch side	Push	42 inches (1065 mm) ⁴	24 inches (610 mm)

1. Add 12 inches (305 mm) if closer and latch are provided.
2. Add 6 inches (150 mm) if closer and latch are provided.
3. Beyond hinge side.
4. Add 6 inches (150 mm) if closer is provided.


TABLE 404.2.4.2
MANEUVERING CLEARANCES AT DOORWAYS WITHOUT DOORS OR GATES, MANUAL SLIDING DOORS, AND MANUAL FOLDING DOORS

Minimum Maneuvering Clearance		
Approach Direction	Perpendicular to Doorway	Parallel to Doorway (beyond stop/latch side unless noted)
From Front	48 inches (1220 mm)	0 inches (0 mm)
From side ¹	42 inches (1065 mm)	0 inches (0 mm)
From pocket/hinge side	42 inches (1065 mm)	22 inches (560 mm) ²
From stop/latch side	42 inches (1065 mm)	24 inches (610 mm)


1. Doorway with no door only.
2. Beyond pocket/hinge side.




12 FIGURE 307.2
LIMITS OF PROTRUDING OBJECTS
NOT TO SCALE




13 FIGURE 307.3
POST-MOUNTED PROTRUDING OBJECTS
NOT TO SCALE



14 FIGURE 307.4
VERTICAL CLEARANCE
NOT TO SCALE



15 SECTION 505.10
HANDRAIL EXTENSIONS
NOT TO SCALE



16 FIGURE 404.2.3
CLEAR WIDTH OF DOORWAYS
NOT TO SCALE

11 TABLES 404.2.4.1 AND 404.2.4.2
MANEUVERING CLEARANCES
NOT TO SCALE

New Kitchen
Facility for



701 Boutwell Road
Lake Worth, FL. 33461



Project No. 22.046
24 February 2023
Bidding, Permit and
Construction

ADA
1.0

of 3