


A PULL-OUT ULTIMATE LOAD TEST SHALL BE PERFORMED FOR POWDER-DRIVEN STUDS ON FOUR REPRESENTATIVE SAMPLES, AT 1200 LBS. IF ANY ANCHOR FAILS, ONLY LEAD EXPANSION ANCHORS SHALL BE USED. INSTALLATION SHALL BE IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS. PIPING 4" AND LARGER SHALL UTILIZE LEAD EXPANSION ANCHORS.


## UPPER ATTACHMENT TO STRUCTURE

SCALE: NONE




## REFRIG. PIPE RISER SUPPORT DETAIL

SCALE: NONE




## CONDENSATE DRAIN DETAIL

SCALE: NONE



## FLOOR PENETRATION DETAIL

SCALE: NONE




- (A) FIELD FABRICATED SLEEVE MAY BE PERMITTED. SUBMIT DETAIL FOR APPROVAL.
- (B) MANUFACTURER'S U.L. APPROVED INSTALLATION INSTRUCTIONS (CONFORMING TO U.L. 555 & NFPA 90A) GOVERN.

## FIRE DAMPER DETAIL

FLUSH MOUNTED GRILLE

SCALE: NONE




## A.H.U. CONDENSATE DRAIN DETAIL

SCALE: NONE


### AHU CONDENSATE DRAIN NOTES

- CONDENSATE PIPING SHALL BE SUPPORTED FROM ROOF AT 4'-0" (MIN) INTERVALS TO MAINTAIN 1/4" SLOPE. CONTRACTOR SHALL SUBMIT SHOP DRAWING TO ENGINEER FOR REVIEW OF CONDENSATE SUPPORT.
- CONDENSATE DRAIN SHALL BE PIPED FULL SIZE OF UNIT CONNECTION
- CONDENSATE PIPING SHALL BE INSULATED PER SPECIFICATIONS.



## VAV TERMINAL BOX DETAIL

SCALE: NONE



## ADJUSTABLE CONDENSING UNIT BASE DETAIL

NOTES: FASTENING OF HURRICANE STRAP TO UNIT WITH TEK SCREWS WILL VOID MANUFACTURES WARRANTY AND IS NOT PERMITTED IN THIS APPLICATION.

SCALE: NONE

Stephen Boruff, AIA  
Architects + Planners, Inc.  
AAC 002226  
Architecture  
Planning  
Interior Architecture

901  
Northpoint Parkway  
Suite 101  
West Palm Beach  
Florida 33407

J L JOHNSON, LEVINSON  
R D BAKER, DAYVA, INC.  
1450 Centrepark Boulevard, Suite 350  
West Palm Beach, Florida 33411  
(561) 688-2303 (561) 688-2302 Fax  
www.jlrline.com

Ruben Ortega Blanco, P.E. 90645  
Ward C. Connors, P.E. 45639

New Kitchen  
Facility for



701 Boutwell Road  
Lake Worth, FL 33461



Project No. 22.046  
24 February 2023  
Bidding, Permit and  
Construction

M  
9

JLRD PROJECT NO:  
122110