

1 DOCK LEVELER DETAIL
NTS



2 GROUNDING CONNECTION TESTWELL DETAIL
NTS

DETAIL NOTES:

TEST WELL/GROUND ROD CONNECTION SHOWN IN THIS DETAIL. CONNECTION TO ORDINARY GROUND RODS SHALL BE DONE IN A SIMILAR MANNER, BUT WITH A WELDED CABLE CONNECTION IN LIEU OF BOLTED CABLE CONNECTION.



3 BUILDING STEEL CONNECTION TO GROUND ROD
NTS



4 DOWN CONDUCTOR TO GROUND RING CONNECTION
NTS



5 TYPICAL BONDING / SPLICING DETAIL
NTS

DETAIL NOTES:

CONNECTORS SHALL BE LISTED AND LABELED BY AN NRTL AND FROM AN ACCEPTABLE MANUFACTURER IN COMPLIANCE WITH PROJECT SPECIFICATIONS SECTION 26 05 26



6 CLASS I ALUMINUM AIR TERMINAL DETAIL
NTS



7 GROUND BAR DETAIL
NTS

THIS DOCUMENT CONTAINS DATA THAT IS CONFIDENTIAL AND IT MAY NOT BE COPIED OR DISCLOSED, AND MAY BE USED BY THE CLIENT ONLY IN THE CONTEXT AND FOR THE EXPRESS PURPOSE FOR WHICH IT WAS INTENDED. ANY USE OF, OR RELIANCE ON, THIS DOCUMENT BY ANY THIRD PARTY IS AT THAT PARTY'S SOLE RISK.

ISOMER PROJECT GROUP
115 WELBORN ST., SUITE A
GREENVILLE, SC 29601
www.isomer.group

REV	DATE	REVISION & ISSUE HISTORY	DES	CHK	APP
0	24AUG23	ISSUED FOR CONSTRUCITON	KCB	NRR	JNC

NICHOLAS R. ROMANO — No. 96560 — STATE OF FLORIDA — PROFESSIONAL ENGINEER
8/24/2023
ISSUED FOR CONSTRUCTION
STAMP / SEAL

SCALE AS NOTED

tellus plant product planet

WAREHOUSE EXPANSION
TELLUS PRODUCTS, LLC.
37021 GATOR BLVD
BELLE GLADE, FL 33430

ISOMER

DOCUMENT TITLE
ELECTRICAL
TYPICAL DETAILS
SHEET 1 OF 2

PROJECT NO.	DRAWING NO.	REV.
TEL2305	EL-DET-0001	0

ARCH D-24x36