


WASTE RISER DIAGRAM  
NO SCALE

LEGEND  
—— SANITARY SEWER  
- - - - VENT

NOTES:  
1.) Water closets are back spud units.  
2.) Urinals are top spud units.



WATER RISER DIAGRAM  
NO SCALE

LEGEND  
—— COLD WATER  
- - - - HOT WATER  
- - - - FILTERED WATER  
[ ] W.H.A. WATER HAMMER ARRESTOR

PLUMBING FIXTURE SCHEDULE				
MARK	DESCRIPTION	C.W.	H.W.	DATE
WC-1	AIS 3453.001 back spud with AIS Selectronic DC power flushometer valve	1"	4"	2"
WC	AIS 3453.001 back spud with AIS Selectronic DC power flushometer valve	1"	4"	2"
Lav - 1	AIS 9024.002 EC with AIS 7755.305 Selectronic faucet	1/2"	2"	1 1/2"
Lav.	AIS 051420.020 with AIS 7755.305 Selectronic faucet	1/2"	2"	1 1/2"
WF	Water filter - ice maker & refrigerator	1/2"	2"	1"
EW-1	Elbay EZSBL with gray cabinet	1/2"	2"	2"
FS	Zum Z-1900 (12" X 12" grate)	-	3"	2"
FD	Floor drain - Zum RZ-415 with type 9" strainer	1/2"	3"	2"
UR	AIS 6590.001 with AIS Selectronic faucet (top spud)	1/2"	2"	2"
UR-1	AIS 6590.001 with AIS Selectronic faucet (top spud)	1/2"	2"	2"
Map Sinks	Flawstone MBSA-2424 with MS 370, 371, 372, 373 & 374, 375 & 377 (24")	1/2"	1/2"	3"
EW4	Rheem ProPlus E40M2EC-1	1/2"	1/2"	-
S-1	Moen GS15443 sink with Moen 8775SMF 12 faucet	1/2"	1/2"	1 1/2"
S-2	Moen GS15212 with Moen 7755-1 1/2" faucet	1/2"	1/2"	1 1/2"
Trap Primer	PPP, Inc. "Prime Rite" PR500	1/2"	-	-
Exp. Tank	Backstop RA101	-	-	-
Disposal	InSinkerator Badger 5	-	-	-
Ice maker	T.B.D.	1/2"	3"	2"
BFPD	Watts LF-007	1/2"	-	-
HB	Zum RZ-1330XL	1/2"	-	-

PLUMBING NOTES:  
1.) Furnish all accessories for a complete installation.  
2.) Equal substitutions are permitted subject to Owner's approval prior to bid.  
3.) Waste and vent piping shall be Schedule 40 PVC. Slope 3" and larger minimum 1/8"/ft. and 2" and smaller minimum 1/4"/ft.  
4.) Faucets shall be CG GPM at 60 PSI.  
5.) Finestop all picking penetrations thru rated assemblies.  
6.) Hot water temperature shall be 110°F to public lavatories.  
7.) S.V. denotes Shodor-Vent air admittance system.  
8.) Water piping shall be copper (or CPVC) and have shut-off valves/stops at all fixtures and WPA (welder hammer armatures) to Code.  
9.) Exposed hot and cold water pipes and traps at sinks and lavatories shall be chrome. Concealed piping shall be PVC.  
10.) Hot water supply and drain line at exposed piping of all lavatories shall be protected with Broun Trap-Wrap (no substitutions).  
11.) Areas above ceilings are no return air plenums.  
12.) Plumbing fixture count meets or exceeds 2020 FBC - Plumbing, Table 403.1.  
13.) All faucets shall have touchless rated flow.  
14.) SEE KITCHEN EQUIPMENT SCHEDULE FOR ADDITIONAL FIXTURES. CONTRACTOR SHALL FURNISH WATER AND SEWER TO ALL FIXTURES AT KITCHEN EQUIPMENT SCHEDULE.

REVISIONS	BY

NEW ATHLETIC / FELLOWSHIP BUILDING


HOBE SOUND BIBLE COLLEGE

11924 S.E. GOMEZ AVE.  
HOBE SOUND, MARTIN COUNTY, FLORIDA

STATE OF FLORIDA  
REGISTERED ARCHITECT  
AR9481

ARCHITECTS  
LICENSE #AAC-001656  
(561) 682-1009

925 SOUTH MILITARY TRAIL, SUITE D-10  
WEST PALM BEACH, FLORIDA 33415



EW4 #1 DETAIL AT JANITOR CLOSET  
NO SCALE